G-74

आज़ादी का अमृत महोत्सव

# GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
# HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
# NEW DELHI-110001

No.F.6 DFS/MS/School/2024/SZ/983 Dated: 07/10/2024

## FIRE SAFETY CERTIFICATE

Certified that **Lalit Mahajan SVM School,** located at **Vasant Vihar New Delhi - 110057** comprised of Ground plus Three Upper Floors owner/occupied by Samarth Shiksha Samiti Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/803 Dated 30/09/2021. The said premise was re-inspected by officer concerned of this department on 30/09/2024 in presence of Ms. Madhu Gupta (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational Building Group – B" (Ground plus Three Floor only)** with effect from 07/10/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 07/10/2024 at New Delhi by

**(ATUL GARG)**
**DIRECTOR**
**DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Lalit Mahajan SVM School, Vasant Vihar New Delhi - 110057
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

## Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."